

CERTIFICATE OF COMPLIANCE

Certificate Number 20180621-EX27724
Report Reference EX27724-20180620
Issue Date 2018-JUNE-21

Issued to: Goodluck Metallics
Village Sikra
taluka Bhachau (Kutch) Gujarat 370140 INDIA

**This is to certify that
representative samples of** METALLIC SPRINKLER PIPE
SEE ADDENDUM PAGE

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 Metallic Sprinkler Pipe For Fire Protection Service
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180621-EX27724
Report Reference EX27724-20180620
Issue Date 2018-JUNE-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

All the below pipes are ERW and are constructed from hot rolled steel coils that conform to ASTM and ASME standards as indicated below.

All pipes with threaded ends shall conform to ANSI B1.20.1.

Schedule 10 steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2 1/2, 3, 4, 6, 8 and 10 in. sizes, as per ASTM A135, Grade B, Type E.

Schedule 10 steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2 1/2, 3, 4, 6, 8 and 10 in. sizes, as per ASTM A795, Grade B, Type E.

Schedule 20 steel pipe in the 8 and 10 in. sizes, as per ASTM A53, Grade B, Type E.

Schedule 30 steel sprinkler pipe in the 8 and 10 in. sizes, as per ASTM A53, Grade B, Type E.

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2 1/2, 3, 4, 5, 6, 8 and 10 in. sizes, as per ASTM A53, Grade B, Type E.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

